

# STRUCTURAL DESIGN REQUIREMENTS FOR MULTI-SECTION DAMPER ASSEMBLIES


## REQUIREMENTS:

- Intermediate structural support is required to resist applied pressure loads for dampers that consist of two or more sections in both height and width. (See below.)
- Tubular steel structural support may be required for large multi-sectioned dampers.
- A non-insulated TAMCO damper weighs approximately 5 lbs/ft<sup>2</sup>. An insulated TAMCO dampers weighs approximately 6 lbs/ft<sup>2</sup>.

## MAXIMUM DEFLECTION:

- The structure providing intermediate support must be designed to resist the highest pressure load, with deflection of less than  $L/320$ . This applies whether the pressure load is created by the mechanical system, by wind load, or if the damper is mounted on the exterior of the building.

**Intermediate, field-supplied, structural support is required when installing in both the vertical and horizontal planes.**



## STRUCTURAL SUPPORT DESIGN FOR TAMCO DAMPERS

### Example:

Design the structural support required to carry TAMCO dampers at the 17th story of a building in Ottawa, Ontario, Canada. (Assuming that the maximum internal pressure, as a result of the mechanical systems, is 2 inches of water, 10.4 psf or 500 Pa.)

### Analysis:

Net wind pressure on damper = exterior pressure or suction + interior pressure in the mechanical plenum (as specified by the mechanical engineer)

$$p = qC_eC_gC_p \text{ external} + 10.4 \text{ psf} \quad \text{1997 OCB 4.1.8}$$

Where:  $p$  = the specific external pressure acting statically and in a direction normal to the surface, either as a pressure directed towards the surface or as a suction directed away from the surface.

$q$  = the reference velocity pressure based on a 1 in 30 probability of being exceeded in any one year for design of structural members for strength.  
 $q_{1/30} = 7.72 \text{ psf}$  (0.37 kPa in Ottawa, Ontario).

$C_e$  = exposure factor based on the height of the building (1.4 for a 170 ft. high building).

$C_g$  = gust factor (2.5 for cladding elements and small structural components).

$C_p$  = external pressure coefficient (1.0 for high local suction).

$$p = qC_eC_gC_p \text{ external} + 10.4 \text{ psf}$$

$$p = 7.72 \text{ psf} (1.4) (2.5) (1.0) + 10.4 \text{ psf}$$

$$p = 37.4 \text{ psf}$$

Total net factored pressure:

$$p_f = 1.5 \text{ (live wind load)}$$

$$p_f = 1.5 \cdot (37.4)$$

$$p_f = 56.1 \text{ psf} \quad (2.7 \text{ kPa})$$

Factored distributed load over vertical support framing member:

$$w_f = 56.1 \text{ psf} (5')$$

$$w_f = 281 \text{ lb./ft.}$$

Factored maximum moment:

$$M_f = w_f l^2/8$$

$$M_f = 281 \cdot (10)^2/8$$

$$M_f = 3513 \text{ lb./ft.} \quad (4.8 \text{ kN}\cdot\text{m})$$

### Assumptions:

The subject building is 17 floors high and has plan dimension of 120' by 120' (36.6 m by 36.6 m). The dampers will be mounted on vertical framing members spanning from the 17th floor to the roof slab level.

Resisting moment:

$M_r$  has to be equal to or greater than  $M_f$  for an unsupported length of 10' (3.05 m)

Acceptable vertical support member:

**C4 x 6.0** - 4" structural steel channel

(metric designation C100 x 9)

$M_r = 3980 \text{ lb.ft.}$  for an unsupported length ( $L_u$ ) = 13'.

( $M_r = 5.4 \text{ kNm}$  at  $L_u = 4\text{m}$ )

Check deflection criteria:

Maximum allowable deflection is  $L/320 = 10'/320 = 0.375"$  (9.5 mm)

Maximum deflection at mid-height of the channel:

$$\Delta = \frac{5 w l^4}{384 E I}$$

For deflection, the reference velocity pressure,  $q$ , is based on a 1 in 10 probability of being exceeded in any one year.  $q_{1/10} = 6.27 \text{ psf}$  (0.30 kPa in Ottawa, Ontario).

$$p = qC_eC_gC_p \text{ external} + 10.4 \text{ psf}$$

$$p = 6.27 \text{ psf} (1.4) (2.5) (1.0) + 10.4 \text{ psf}$$

$$p = 32.3 \text{ psf}$$

$$w = 32.3 \text{ psf} (5')$$

$$w = 162 \text{ lb./ft.}$$

$$\Delta = \frac{5 (162 \text{ lb./ft.}) (10')^4}{384 (29,000 \text{ ksi}) (4.25 \text{ in}^4)}$$

$$\Delta = \frac{5 (13.5 \text{ lb./ft.}) (120'')^4}{384 (29 \cdot 10^6 \text{ psi}) (4.25 \text{ in}^4)} = 0.30 \quad (7.6 \text{ mm})$$

Therefore, an acceptable vertical support member for this example is a **C4 x 6.0** (metric designation C100 x 9).